Lecture 16: Real-Time Networks and Networked Control Systems

[These slides]

- Background
- Real-Time Networks
- Protocol Stack
- Network Examples
 - CAN – TTP
- Networked Control Systems

These slides are partly based on material from Luis Almeida, Universidade de Aveiro, Portugal


Background

Distributed architectures are pervasive in many application fields:

- Industrial automation
- Transportation systems (airplanes, cars, trucks, trains, ...)
- Multimedia systems (remote surveillance, industrial monitoring, video on demand, ...)

In many cases with **critical timeliness** and **safety** requirements

Increasingly common that control loops are closed over networks (= networked control)



Background

Motivations for distributed architectures:

- Processing closer to data source /sink
 - · "Intelligent" sensors and actuators
- Dependability
 - · Error-containment within nodes
- Composability
 - System composition by integrating subsystems
- Scalability
 Easy addition of new nodes with new or replicated functionality
- MaintainabilityModularity and easy node replacement
 - · Simplification of the cabling

Background

Today there are many different networks with real-time capabilities aiming at different application domains, e.g.

- ATINC629, SwiftNet, SAFEbus avionics
- WorldFIP, TCN trains
- CAN, TT-CAN, FlexRay cars
- ProfiBus, WorldFIP, P-Net, DeviceNet, Ethernet automation
- Firewire, USB multimedia


VW Phaeton

- 11,136 electrical parts
- 61 ECUs (Electronic Controller Units == CPUs)
- Optical bus for high bandwidth infotainment data
- 35 ECUs connected by 3 CAN-busses sharing
 - 2500 signals
 - In 250 CAN messages



The VW Phaeton
Adapted from (Loehold, WFCS2004)

Volvo XC 90 network topology



Contents

- Background
- · Real-Time Networks
- · Protocol Stack
- · Network Examples
 - CAN
 - TTP
- · Networked Control Systems


Service requirements

Typical service requirements in real-time networks:

- Efficient transmission of short data (few bytes)
- Periodic transmission (control, monitoring) with short periods (ms), low latency, and small jitter
- Fast transmission (ms) of aperiodic requests (alarms, commands, ...)
- Transmission of non-real-time data (configuration information, log data, ...)
- Multicasting as well as unicasting (peer to peer)


The Network in a Distributed System

- The network is a fundamental component in a distributed system supporting all the interactions among the nodes
- Hence, it is also a critical resource since loss of communication results in the loss of all global system services



Network Interfaces

The network extends up to the Communication
 Network Interface (CNI) that is the interface between
the communication systems and the node host



Messages & Transactions

- Interactions are supported by message passing
- A message is a unit of information that should be transferred at a given time from a sender to one or more receivers
- Contains both the data and the control information that is relevant for the proper transmission of the data (e.g., sender, destination, checksum, ...)
- A network transaction is the sequence of actions within the communication systems required to transfer the message
- Might include messages containing only control information, i.e., control messages
- Some networks automatically break large messages into smaller packets (fragmentation/reassembly)
- A packet is the smallest unit of information that is transmitted
- The data efficiency of the network is the ratio between the the time to transmit effective data bits and the total duration of the transaction

Timing Figures

- Typical figures concerning the temporal behaviour of the network:
 - Network induced delay extra delay caused by the transmission of data over the network. Some applications, e.g., control, are very sensitive to this
 - Delay jitter variations in the network induced delay. Some applications, e.g., multimedia streaming, are very sensitive to this, but not so sensitive to the delay.
 - Buffer requirements when the instantaneous transmission from a node is larger than the capacity of the network to dispatch, the traffic must be stored in buffers. Too small buffers lead to packet losses
 - Packet loss probability packet losses can in addition to the above also be caused by unreliable network media. One example of this is wireless networks.

Timing Figures, cont

- Throughput (bandwidth) amount of data, or packets, that the network dispatches per unit of time (bit/s and packet/s)
- Arrival/Departure rate rate at which data arrives at/from the network
- Burstiness measure of the traffic submitted to the network in a short interval of time. Bursts may have a negative impact on the real-time performance of the network and impose high buffering requirements. Traffic shaping can be used to control the characteristics of the traffic generated by a node.

Real-Time Messages

- Real-time messages can have event or state
 semantics
- Events are perceived changes in the the system state.
 All events are significant for the state consistency across sender and receiver
- Event messages must be queued at the receiver and removed upon reading. Correct order in delivery must be enforced.
- State messages (containing state data) can be read many times and overwrite the values of the previous message concerning the same real-time entity

Event or Time Triggering


- According to the type of message (event or state) conveyed by the network, it can be
 - Event-triggered (event messages)
 or
 Time-triggered (state messages)

 Temperature is 15 C

 Temperature raised by 2 C

 Temperature raised by 2 C

Event-Triggered Network




Time-triggered Network

There is a notion of network time

Temperature sensor node

- All clocks are globally synchronized
- Transactions carrying state data are triggered at predefined time instants
- · Receivers have a periodic refresh of the system state
- · The submitted communictaion load is well determined

Time-Triggered Network



Event vs Time Triggering

Time-triggered networks:

- Are more deterministic
 - · Transmission instants are predefined
- · Fault-tolerance mechanisms are easier to design
- Are less flexible in reacting to errors
 - Retransmissions are often not possible because the traffic schedule is fixed
 - A lost message is not recovered until the next period of the message stream
- Are less flexible with respect to changes
 - Everything must be known a priori and very little can be changed dynamically (cp. static cyclic CPU scheduling)
- The communication protocols are often quite complex

Event vs Time Triggering


Event-Triggered Networks:

- Low level of determinism
 - · Events can occur at any time
- More complex fault-tolerance schemes
- Very flexible with respect to errors
 - · Retransmissions can be carried out immediately
- The communication protocols are normally quite simple


Contents

- Background
- · Real-Time Networks
- Protocol Stack
- · Network Examples
 - CAN
 - TTP
- · Networked Control Systems


The OSI Protocol Stack



Protocol Stack



Layer Interfaces




Very large computing and communication **overhead** for short real-time data traffic!!

Real-Time Protocol Stack

- The end-to-end communication delay must be bounded
 - All services at all layers must be time-bounded
 - Requires appropriate time-bounded protocols
- The 7 OSI layers impose a considerable overhead...
- Many real-time networks
 - are dedicated to a well-defined application (no need for presentation)
 - use single network domain (no need for routing)
 - use short messages (no need to fragment/reassemble)

Collapsed OSI Model


- · Application accesses the Data Link directly
- · Other layers may be present but are not fully stacked
- · In industrial automation these networks are called fieldbuses



Physical Layer

- · Interconnection topology
- · Physical medium
- · Coding of digital information
- · Transmission rate
- · Maximum interconnection length
- · Max. number of nodes
- Immuniy to EMI (Electro-magnetic interference)

Physical Layer: Topology



Physical Layer: Medium

- · Copper wiring
 - Cheaper cables and interfaces (+), suffers EMI(-)
- Optical fibres
 - Immune to EMI, wide bandwidth, low attenuation (+), expensive cables and interfaces (-)
- Wireless Radio Frequency (RF)
 - Mobility, flexibility (+), very susceptible to EMI (-), multi-path fading (-), attenuation (-), open medium (+/-)
- Wireless Infra-red light (IR)
 - Mobility, flexibility (+), line-of-sight (-), open medium (+/-)

Data Link Layer

Issues related to:

Star

- Addressing
- Logical Link Control (LLC)
 - · Transmission error control
- Medium Access Control (MAC)
 - · for shared media

Data Link Layer: Addressing

- · Direct addressing
 - The sender and receiver(s) are explicitly identified in every transaction, using physical address (MAC addresses in Ethernet)
- · Indirect (source) addressing
 - The message contents are explicitly identified (e.g. temperature of sensor X). Receivers that need the message retrieve it from the network (as in CAN)
- · Indirect (time-based) addressing
 - The message is identified by the time instant at which it is transmitted (as in TTP – Time Triggered Protocol)

Data Link Layer: LLC

- · Logical Link Control (LLC)
 - Deals with the information transfer at this level
 - Upper sub-layer of the data link layer
 - Typical services are:
 - Send with immediate acknowledge
 Sender waits for acknowledge from receiver
 - · Send without acknowledge
 - No synchronization between data and receiver
 - · Connection-oriented services

A connection must be established between parts before any communication may take place

Data Link Layer: Transmission Error Control

Part of the LLC

Specifies error detection and action upon this. Typical actions are

- Forward error correction (FEC)
 - Error correcting codes (more related to the physical layer)
- Automatic Repeat reQuest (ARQ)
 - The receiver triggers a repeat request upon error
- Positive Acknowledgement and Retry (PAR)
 - The sender resends if ACK is not received

From a real-time perspective, ARC and PAR may induce longer delivery delays as well as extra communication load


Data Link Layer: MAC

Medium Access Control (MAC)

- Lower sub-layer of the data link layer
- Determines the order of the network access by contending nodes and, thus, the network access delay
- Is of paramount importance for the real-time behaviour of networks that use a shared medium

MAC: Master-Slave


- · Access is granted by the Master node
- · Nodes synchronized with the master
- · Requires one control message per data message



• Ex. WorldFIP, Ethernet Powerlink, Bluetooth (within piconets)

MAC: Token Passing

- · Access is granted by the possession of a token
- · Order of access enforced by token circulation
- · Real-time operation requires bounded token holding time




• Ex. FDDI, PROFIBUS

MAC: TDMA

Time-Division Multiple Access

- Access granted in a dedicated time-slot
- Time slots are pre-defined in a cyclic framework
- Requires global clock syncronization
- High data efficiency
- Typically uses static table-based scheduling





- Ex. TTP/C, TT-CAN, PROFINET

MAC: CSMA

Carrier-Sense Multiple Access:

- Set of protocols based on sensing bus inactivity before transmitting (asynchronous bus access)
- There may be collisions
- Upon collision, nodes back off and retry later, according to some specific rule (this rule determines to a large extent the real-time features of the protocols)

MAC: CSMA/CD

Carrier-Sense Multiple Access with Collision Detection

- Used in shared Ethernet (hub instead of switch)
- Collisions are destructive and are detected within collision window
- Upon collision, the retry interval is random and the randomization window is doubled for each retry until 1024 slots
- Non-deterministic (e.g., chained collisions)
- Not suitable for a real-time network. However.
 - The physical Ethernet layer is often used in real-time networks.
 - It is possible to get real-time performance on an Ethernet network, if the access to the medium is scheduled in some way, i.e., collisions are avoided

MAC: CSMA/BA

Carrier-Sense Multiple Access with Bit-Wise Arbitration

- Bit-wise arbitration with non-destructive collisions
- Upon collision, highest priority node is unaffected. Nodes with lower priorities retry right after
- Determinsitic
- E.g. CAN
- Sometimes also called CSMA/CR (Collision Resolution) or CSMA/CA (Collision Arbitration), although the lattter really is something else

Contents

- Background
- · Real-Time Networks
- Protocol Stack
- Network Examples
 - CAN
 - TTP
- Networked Control Systems

CAN


- · Controller Area Network
- · Created by Bosch for use in the automotive industry
- · Used in most European cars today
- · Adopted by GM as an in-house standard
- Expanded to industrial automation
- · Defines physical and data link layer
- Multi-master, broadcast, serial bus
- Transmision rate from 5 Kbit/s to 1 Mbit/s
- Small sized messages 0-8 bytes
- Relatively high overhead (47 bits + stuff bits)
- On transmission, nodes synchronize on bit level

CAN

- · Can is like Ethernet ...
 - Everybody with a message to send waits until the bus is quiet, then starts transmitting, and if a node detects a collision it backs off and retries later
- · ... but more deterministic
 - A CAN bus has a special electrical property that allows it to handle collisions better

The CAN Protocol

- Messages are called frames
- · A frame is tagged by an identifier
 - Indicates the contents of the frame (used for addressing)
 - Used in the arbitration for prioritizing frames (the frame with the lowest identifier is selected to send in case of collision)
- The CAN physical layer behaves as a wired AND, i.e. if any node sends a logical 0, then all nodes receive 0 bit.



Bit Stuffing

- · CAN frames are bit stuffed.
 - If 5 bits in a row are the same sign then the protocol inserts a bit of the opposite sign
 - Used to ensure enough edges to maintain synchronization
 - Used to distinguish data frames from special error handling frames

- · All nodes receives all frames
- The handling of the CAN bus communication within a node is done by a special CAN controller (card/chip)
- The CAN controller throws away frames not needed by the node using ID filtering hardware
- Messages that are waiting to be sent are queued in a priority sorted list in the CAN controller.

The Basic Protocol

- Frames start by sending the identifier field most significant bit first
- When sending the identifier the frame is in arbitration
 - other frames may be sent too
 - need to find the highest priority frame
- If a node sends a 1 (recessive bit) but reads back a 0 (dominant bit) then it gives up and backs off
 - there must be a higher priority frame being sent
- Restarts sending the same frame when the bus is idle again

Arbitration

Bus		1	
Frame 3	1498	1	
Frame 2	1306	1	
Frame 1	1344	1	

Arbitration

Bus		10
Frame 3	1498	10
Frame 2	1306	10
Frame 1	1344	10

Arbitration

Frame 2 Frame 3	1306 1498	101
Bus	1470	101

Arbitration


Bus		1010
Frame 3	1490	1011
Frame 2	1306	1010
Frame 1	1344	1010

Arbitration

Frame 1	1344	10101
Frame 2	1306	10100011010
Frame 3	1470	1011
Bus		130 8001 1010

CAN and hard real-time

- Need to know the worst-case frame latencies (end-to-end delay)
- Through testing



- Through analysis
 - Fixed priority scheduling theory can be applied
 - Bus = shared resource, cp CPU
 - Frame = job (invocation of a task)

TTP - Time Triggered Protocol

- Not just a network, more of a architecture
- Shared broadcast bus, 2-25 Mbit/s
- Popular in car industry for safety-critical applications, e.g., X-by-wire
- · Design goals
 - Fault-tolerance
 - Messages latencies that are easy to calculate and have no latency

- · Mostly periodic messages
- · Replicated broadcast communication channels
- Replicated nodes are grouped into FTUs Fault Tolerant
 Units
- · Access to the network through TDMA (statically allocated)



 More deterministic than CAN (cp. static scheduling vs dynamic scheduling)

TTP Design

- Message transport with predictable low latency: simple protocol with known WCET & minimal overhead
- Fault tolerance: allow node and network failures without loss of functionality
- · High precision clock synchronization
- · Off-line network traffic scheduling
- TTP info
 - TTTech (www.tttech.com)
 - TTP Forum (www.ttpforum.org)

FlexRay

TTP competitor

Developed by European car manufacturers

Combines time-driven and event-driven communication


Event-driven communication allowed in special slots in the TDMA structure

Similar extensions are also possible in TTP

Contents

- Background
- · Real-Time Networks
- · Protocol Stack
- Network Examples
 - CAN
 - TTP
- Networked Control Systems


Networked Control Systems





- · Networked Control System
 - wired or wireless

Networked Control Structures

A networked control system is a spatially distributed control system with sensor, actuator and controller communication supported by a network









Networked Control Loop Timing

- · Networked embedded control implies temporal non-determinism
 - network communication
 - real-time scheduling
- · Degraded control performance due to
 - sampling interval jitter
 - non-negligible input-output latencies with jitter
 - lost samples
- However
 - Most control loops are fairly robust towards temporal non-determinism
- network interface processing delay
- queuing delaytransmission delay
- propagation delay
- link layer resend delay
- transport layer ACK delay
-

Control under network delay

- Delays in communication due to buffering, propagation delays, collisions/resends,
- · Delays can be fixed or varying, known (measurable) or unknown





Clocks and Time Stamps



- The controller must know when the data was sampled/sent in order to compensate for varying network latencies
- · Approaches:
 - Global clock
 - clock synchronization
 - complexity overhead
 - Local clocks
 - associate time-stamps with data packets
 - absolute or relative
 - OK if the data always comes from the same sensor node
 - A problem if the source node of the data changes

Compensate for Input-Output Delays

Sampled model with varying delay τ_k :

$$x(k+1) = \Phi x(k) + \Gamma_0(\tau_k)u(k) + \Gamma_1(\tau_k)u(k-1)$$

• Design the feedback

$$u(k) = -L \left(\begin{smallmatrix} \hat{x}(k) \\ u(k-1) \end{smallmatrix} \right)$$


Or, let the feedback be dependent on the actual delay

based on the average (expected) input-output delay

• Modify the observer to take into account current delay τ_k :

$$\hat{x}(k+1) = \Phi \hat{x}(k) + \Gamma_0(\tau_k)u(k) + \Gamma_1(\tau_k)u(k-1) + K(y(k) - C\hat{x}(k))$$

Compensate for Network Delays




Only Part of the current loop delay ($\tau_{\rm sc}$) can now be measured!

- ullet Time-varying state feedback L_k based on au_{sc}^k + $\mathrm{E}\{ au_{ca}\}$
- Let the actuator node record the total delay
- The total delay is communicated back to the controller
- Make the observer time-varying as before

Cross-Layer Design

- Control applications can often adapt to varying network conditions
- Network information needed at application layer → cross-layer designs
- Specially important if full OSI or IP protocol stacks are used



Sensor to Controller:
• when collision happens
• resample rather than resend old data

General Conclusions

- Real-time communication increasingly important in several fields
- The traditional OSI/IP stacks are not well suited for realtime networks
- Collapsed OSI stack (physical, data link, application) better for real-time networks
- Networked control systems increasingly common
- Problems with delays, jitter and lost packets if non-real time networks are used
- Can partly be compensated for by control methods
- In wireless systems the problems become worse